



**JONATHAN E. FIELDING, M.D., M.P.H.**  
Director and Health Officer

**JONATHAN E. FREEDMAN**  
Chief Deputy Director

**ANGELO J. BELLOMO, REHS**  
Director of Environmental Health

**JACQUELINE TAYLOR, REHS**  
Director of Environmental Protection Bureau

**PATRICK NEJADIAN, REHS**  
Chief EHS, Land Use Program

**Thao Komura, REHS**  
Environmental Health Staff Specialist  
Land Use Program  
5050 Commerce Drive  
Baldwin Park, California 91706  
TEL (626) 430-5382 • FAX (626) 960-2740

[www.publichealth.lacounty.gov](http://www.publichealth.lacounty.gov)



**BOARD OF SUPERVISORS**

**Gloria Molina**  
First District

**Mark Ridley-Thomas**  
Second District

**Zev Yaroslavsky**  
Third District

**Don Knabe**  
Fourth District

**Michael D. Antonovich**  
Fifth District

Tract Map No. 071735

Vicinity: Malibu

Tentative Tract Map Date: October 31, 2012 (2<sup>nd</sup> Revision)

**The Los Angeles County Department of Public Health** – Environmental Health Division/Land Use program has no comments regarding the approval of **Vesting Tentative Tract Map 071735** as described further on the attached letter.

Prepared by: Thao Komura

A handwritten signature in black ink, appearing to be "TK" or similar initials, written over the name "Thao Komura".

Phone No: (626) 430-5581

Date: December 6, 2012

COUNTY OF LOS ANGELES ♦ DEPARTMENT OF PUBLIC HEALTH

ENVIRONMENTAL HEALTH ♦ LAND USE PROGRAM

5050 Commerce Drive, Baldwin Park, CA 91706

Date: December 6, 2012

Page 1 of 1

Map No. TR 071735

Map Date: October 31, 2012

Land Use program has no comments regarding this project.

---

The project is proposing the use of a Recycled Water Treatment System to serve the wastewater disposal needs of the project. The proposed Recycled Water Treatment System would include a network of septic tanks and holding reservoirs, a water reuse reservoir and an At-Grade or above-ground dispersal system (landscape irrigation) for the disposal of effluent wastewater.

The tertiary treated wastewater system intended to produce recycled water for the purpose of surface irrigation, as described above, shall be regulated under a Waste Discharge Requirement (WDR) permit issued by Regional Water Quality Control Board (RWQCB). Therefore, Land Use program has no further comments regarding this project.

For questions regarding the above requirements, please contact Patrick Nejadian at (626) 430-5390.

Note: The use of recycled water must meet the requirements of Title 22 of the California Code of regulations and other requirements established by the California Department of Public Health and this Department. Prior to installation of the onsite recycled water system, two sets of plans, along with a completed application and fee, must be submitted to the Environmental Health's Cross Connection Program for review and approval. For questions regarding recycled water, please contact Carlos Borja at (626) 430-5295.